



Ed Hassinger, District Engineer

**ADDENDUM 001
REQUEST FOR QUOTATION
SL13-067-R7 St. Peters Parking Lot Paving and Striping Project**

Bidders shall acknowledge receipt of Addendum 001 (ONE) by signing and including it with original bid. The due date for receipt of this bid **does not change** by this Addendum. Accordingly, the following clarifications, additions/deletions, questions and answers are believed to be of general interest to all potential bidders. All other terms and conditions remain unchanged and in full force.

Name and Title of Signer (Print or type)	Name and Title of Department Authority Stephanie Austin Rashid Sr. General Services Technician
Bidder Signature	Department of Transportation <i>Stephanie Austin Rashid</i>
Signature of person authorized to sign	Authorizing Signature
Date Signed:	Date Signed: December 10, 2012

Question 1: The drawing sent along with the bid documents indicates that the majority of the parking lot gets sealed. Is this to be included in our scope?

Answer: No, the sealing of the lot will not be done at this time and is not included in the scope of work.

Question 2: The completion period is two weeks after award. With this being winter, are we given additional time for completion for days that are below say, 50 degrees which is the pretty much the cut off for overlays, getting tack to break and installing a good looking and constructed job?

Answer: The two week completion date can be lifted if needed, based on weather conditions.

Question 3: The plans show to “Seal” part of the lot and they also have a drawing of “ADA Parking Only” sign & post. Are these part of this project?

Answer: Seal edges where new asphalt meets existing. We will not be sealing entire lot at this time. ADA Parking signs are not part of the bid.

VENDOR NOTE: Project is being done so the Highway Patrol Drivers Testing Facility can open this winter. Lot must be striped for the general public.

THIS PAGE MUST BE SIGNED AND RETURNED WITH ORIGINAL RFQ.